

# **Stationary Battery Room Design Review Checklist**

**Approved for public release; distribution unlimited**

**General Medical: 500A, Public Health Data**

**2013**



# Stationary Battery Room Design Review Checklist

**UFC 3-520-05, Stationary Battery Areas, 14 April 2008**

**NFPA 1, Fire Code, 2012 Edition**

**NFPA 70, National Electrical Code, 2011 Edition**

**NFPA 70E, Electrical Safety in the Workplace, 2004 Edition (2012 Edition)**

**NFPA 10, Standard for Portable Fire Extinguishers, 2010 Edition**

**ISEA Z 358.1 -2009, American National Standard for Emergency Eyewash and Shower Equipment (Formerly ANSI Z 358.1)**

**ACGIH Industrial Ventilation Manual, 27<sup>th</sup> Edition**

## Architectural

1. Located near the load being served (UFC 3-520-05)?
2. Are more than one type of battery chemistry (i.e. lead-acid, nickel-cadmium, etc.) being used?  
If so, are they in separate rooms (UFC 3-520-05)?
3. Are occupancy separation requirements between the battery room(s) and other portions of the building met (UFC 3-520-05, NFPA 1)?
4. Services not associated with the battery room will not pass through the room (UFC 3-520-05)?
5. The battery room is not used as access to another space. (UFC 3-520-05)
6. Is the floor covered with a slip-resistant material and acid- or alkali-resistant (UFC 3-520-05)?  
For vented cell installation, are the wall and ceiling finish acid or alkali resistant (UFC 3-520-05)?
7. Is an overhead hoist or portable material handling equipment provided for the room (UFC 3-520-05)?

## HVAC

1. Is the room mechanically ventilated (UFC 3-520-05)?
2. Is the ventilation system designed to maintain hydrogen concentrations in the room below 1% concentration (UFC 3-520-05, NFPA 70E, NFPA 1)?

Equation 1:

$$\text{Hydrogen rate (HR)} = \text{emission rate} \times \text{charging current per 100 Ah} \times \text{doubling factor} \times \frac{\text{cell capacity per 8 hour} \times \text{number of cells}}{\text{increment of cell capacity passing charging current}}$$

Equation 2:

$$\text{Ventilation rate (VR)} = \text{HR}/0.01$$

Note: NFPA 1 requires continuous ventilation at a rate of not less than 1cfm/ft<sup>2</sup> of floor area of the room or cabinet.

3. Is the supply air rate 95% of the exhaust ventilation in order to maintain a negative pressure in the room (UFC 3-520-05, ACGIH 27<sup>th</sup> Ed.)?
4. Is all air exhausted directly outside (UFC 3-520-05)?
5. Is the stationary battery area located along an exterior wall?  
If not, it needs a dedicated exhaust duct system (UFC 3-520-05)?
6. Is makeup air being transferred from a Class 1 or Class 2 area in the facility as defined in ASHRAE 62.1 or supplied directly?  
If supplied directly, is it filtered (UFC 3-520-05)?
7. Are fans roof-mounted with an upwardly directed discharge (UFC 3-520-05)?
8. Is the exhaust fan spark-resistant with an explosion proof motor (UFC 3-520-05)?
9. Are the air inlets no higher than the lowest tier of the battery rack?  
Are the exhaust grilles located at the highest point of the room (UFC 3-520-05)?

10. Is the ductwork made of either polyvinyl chloride (PVC) or fiberglass reinforced plastic (FRP) (UFC 3-520-05)?

11. Is the HVAC system designed for continuous operation (UFC 3-520-05)?

12. Does the exhaust fan have a green indicator light to indicate proper operation (UFC 3-520-05)?

## **ELECTRICAL**

1. Are battery racks, enclosures and cables bonded to ground with #6 AWG (UFC 3-520-05)?

2. Is there overcurrent protection for each battery string (UFC 3-520-05)?

3. Is there a disconnect device where the DC conductors leave the battery room (UFC 3-520-05)?

4. Are room lighting fixtures pendant or wall mounted and not provide a collection point for explosive gas (UFC 3-520-05)?

5. For rooms with vented cell batteries, are the lighting fixtures constructed with corrosion resistant materials (UFC 3-520-05)?

6. Will lighting fixture mounting interfere with the operation of lifting devices (UFC 3-520-05)?

7. Is instrumentation to measure battery, voltage with high and low alarms, battery current, and ground detection for ungrounded systems provided (UFC 3-520-05)?

## **EMERGENCY FACILITIES**

1. Is there a portable or stationary water facility for rinsing eyes and skin provided within 20 feet of the battery (UFC 3-520-05, ISEA Z358.1-2009)?

## **FIRE PROTECTION REQUIREMENTS**

1. Is a smoke detection system installed in the room/area (NFPA 1)?
2. Are portable fire extinguishers provided within and adjacent to the battery room (UFC 3-520-05, NFPA 10)?